

2-447.C

BROOKINGS ORDINANCES

2-447.C

ORDINANCE NO. 90-O-447.C

AN ORDINANCE AMENDING ORDINANCE NO. 89-O-447, WHICH ADOPTED THE GENERAL ENGINEERING REQUIREMENTS AND STANDARD SPECIFICATIONS FOR STREET, STORM DRAIN, SEWER AND WATERLINE CONSTRUCTION DOCUMENT, DATED AUGUST, 1988.

[Ordinance No. 89-O-447.B repealed by Ordinance No. 91-O-484, effective December 9, 1991]

[See Ordinance No. 89-O-447.B in its entirety in original ordinance books]

ORDINANCE NO. 90-O-447.C

AN ORDINANCE AMENDING ORDINANCE NO. 89-O-447, WHICH ADOPTED THE GENERAL ENGINEERING REQUIREMENTS AND STANDARD SPECIFICATIONS FOR STREET, STORM DRAIN, SEWER AND WATERLINE CONSTRUCTION DOCUMENT, DATED AUGUST, 1988.

Sections:

Section 1. Amendment to Ordinance No. 89-O-447.

The City of Brookings ordains as follows:

Section 1. Amendment to Ordinance No. 89-O-447. Ordinance No. 89-O-447 is hereby amended by the following addition:

**Division 3
Sitework**

3N. Culvert Installation

02. Materials.

a. Corrugated Metal Pipe.

(01) Corrugated metal pipe shall be helical corrugated, Armco "Hel-Cor Aluminized Steel, Type 2", or approved equal, conforming to AASHTO M36, Type 2.

(02) Aluminum pipe is approved equal. Kaiser "Corlix" Storm Sewer Pipe, conforming to AASHTO M 196, current edition.

(03) Corrugated metal pipe shall be nominal inside diameters of 12 inches, minimum. Pipe shall be 14 gauge minimum.

(04) Joints shall be made with connecting bands fabricated from same material as pipe. Connecting bands shall be

ten and one half (10-1/2) inches wide for steel, twelve (12) inches wide for aluminum.

[Effective December 18, 1990]

10-447.C

BROOKINGS ORDINANCES

10-447.C

ORDINANCE NO. 90-O-447.C

AN ORDINANCE AMENDING ORDINANCE NO. 89-O-447, WHICH ADOPTED THE GENERAL ENGINEERING REQUIREMENTS AND STANDARD SPECIFICATIONS FOR STREET, STORM DRAIN, SEWER AND WATERLINE CONSTRUCTION DOCUMENT, DATED AUGUST, 1988. [Effective December 18, 1990]

[See "Standard Specifications" document, Division 3, Sitework, for amendments]